

Classification

| | |
|------------------|--|
| Number | 21-003863-PR01 (NW-H05-05-en-01) |
| Owner | GUTMANN P V B PLASTIC SHEETS MANUFACTURING L.L.C Dubai Investment Park 2 Dubai United Arab Emirates |
| Product | Laminated safety glass (LSG) |
| Designation | Shipping name: 13.52 mm Clear Laminated Glass |
| Details | Overall dimensions (W x H) 876 mm x 1938 mm; Glass configuration TSG 6 mm / PVB-Foil 1.52 mm / TSG 6 mm; Measured thickness 13.25 mm; Nominal thickness 13.52 mm; Surface weight 30 kg/m ² |
| Special features | -/- |

Result **)

Classification Pendulum Test according EN 12600



Class: 1 - (B) - 1

Basis *)

EN 12600:2002-11

*) and corresponding national versions (e.g. DIN EN)

Test report: 21-003863-PR01 PB-H05-05-en-01

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

**) Decision rule: For the conformity assessment, the determined measurement results were assumed to be error-free values.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and detailed results given relate solely to the tested/described specimen.

This test does not allow any statement to be made on further characteristics of the present structure regarding performance and quality, in particular the effects of weathering and ageing. The classification will be valid as long as the product remains unchanged and the above bases have not changed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: ABA-E33AA

ift Rosenheim

05.05.2022



Stefan Hehn, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Security/Safety Testing



Khalid El Harada, Dipl.-Ing. (FH)
Operating Testing Officer
Security/Safety Testing